



## MAPLE RIDGE FIRE DEPARTMENT FIRE DEPARTMENT CONNECTIONS

The location of fire department connections must be pre-approved by the Maple Ridge Fire Department

Fire Department Connections in Maple Ridge must comply with the following specifications:

- A 4 inch Storz connection
- Located at the property line to the front (address side) of the property facing the street
- Angled down at a 35-degree angle
- Installed at a height of 1,000 mm (39 inches) above the landscaped ground level
- Hard surfaced pathway from the sidewalk to the FD connection

The following diagram is a guideline only

