

## Sample Range Report

Fraser Health Authority

**Facility Name:** City of Maple Ridge - Firehall #2 Water System

**Date Range:** Jan 1 2020 to Dec 31 2020

**Operator** Michael Albrecht  
11995 Haney Place  
Maple Ridge, BC V2X 6A9

Sampling Site	Date Collected	Total Coliform	E. Coli	Fecal Coliform
<u>AUDIT - Tap, 2</u>				
<u>27501 112 Ave</u>				
	1-28-2020 10:25:00 AM	LT1	LT1	
	3-2-2020 10:35:00 AM	LT1	LT1	
	6-2-2020 9:55:00 AM	LT1	LT1	
	7-15-2020 9:12:00 AM	LT1	LT1	
	9-28-2020 1:08:00 PM	LT1	LT1	
	11-30-2020 9:55:00 AM	<u>LT1</u>	<u>LT1</u>	
	<b>Total Positive:</b>	<b>0</b>	<b>0</b>	<b>0</b>

**Result Values:**                      **E - estimated**                      **L - less than**                      **G - greater than**

Samples that contain total coliform:	0		0.00% of total
Samples that contain e. coli:	0		0.00% of total
Samples that contain fecal coliform:	0		0.00% of total
Number of consecutive samples that contain total coliform:	0		
Number of samples that contain total coliform in last 30 days:	0/0		
Total number of samples:	6		

**Comments:**

\_\_\_\_\_  
Environmental Health Officer  
Jan 20 2021

FOR FURTHER INFORMATION PLEASE CALL: Binny Sivia

## Sample Range Report

Fraser Health Authority

**Facility Name:** Thornhill Hall Water System

**Date Range:** Jan 1 2020 to Dec 31 2020

**Operator** Michael Albrecht  
11995 Haney Place  
Maple Ridge, BC V2X 6A9

Sampling Site	Date Collected	Total Coliform	E. Coli	Fecal Coliform
<u>Audit - Outside hose</u>				
<u>bib, 26007 98th Ave</u>				
	2-12-2020 11:50:00 AM	LT1	LT1	
	3-11-2020 10:45:00 AM	LT1	LT1	
	6-2-2020 9:30:00 AM	LT1	LT1	
	7-15-2020 9:45:00 AM	LT1	LT1	
	11-30-2020 9:05:00 AM	<u>LT1</u>	<u>LT1</u>	
	<b>Total Positive:</b>	<b>0</b>	<b>0</b>	<b>0</b>

**Result Values:**                      E - estimated                      L - less than                      G - greater than

Samples that contain total coliform:	0	0.00% of total
Samples that contain e. coli:	0	0.00% of total
Samples that contain fecal coliform:	0	0.00% of total
Number of consecutive samples that contain total coliform:	0	
Number of samples that contain total coliform in last 30 days:	0/0	
Total number of samples:	5	

**Comments:**

\_\_\_\_\_  
Environmental Health Officer

Jan 20 2021

FOR FURTHER INFORMATION PLEASE CALL: Binny Sivia

## Sample Range Report

Fraser Health Authority

**Facility Name:** Whonnock Community Well Water System

**Date Range:** Jan 1 2020 to Dec 31 2020

**Operator** Mike Gjaltema  
11995 Haney Place  
Maple Ridge, BC V2X 6A9

Sampling Site	Date Collected	Total Coliform	E. Coli	Fecal Coliform
<u>AUDIT - Standpipe,</u>				
<u>10900 272 St</u>				
	2-12-2020 11:30:00 AM	LT1	LT1	
	6-2-2020 9:40:00 AM	LT1	LT1	
	7-15-2020 9:18:00 AM	LT1	LT1	
	11-30-2020 9:40:00 AM	<u>LT1</u>	<u>LT1</u>	
	<b>Total Positive:</b>	<b>0</b>	<b>0</b>	<b>0</b>

**Result Values:**                      E - estimated                      L - less than                      G - greater than

Samples that contain total coliform:	0	0.00% of total
Samples that contain e. coli:	0	0.00% of total
Samples that contain fecal coliform:	0	0.00% of total
Number of consecutive samples that contain total coliform:	0	
Number of samples that contain total coliform in last 30 days:	0/0	
Total number of samples:	4	

**Comments:**

\_\_\_\_\_  
Environmental Health Officer

Jan 20 2021

FOR FURTHER INFORMATION PLEASE CALL: Binny Sivia

## Sample Range Report

Fraser Health Authority

**Facility Name:** Whonnock Lake Community Hall WS

**Date Range:** Jan 1 2020 to Dec 31 2020

**Operator** Michael Albrecht  
11995 Haney Place  
Maple Ridge, BC V2X 6A9

Sampling Site	Date Collected	Total Coliform	E. Coli	Fecal Coliform
<u>AUDIT - Kitchen,</u>				
<u>27871 113 Ave</u>				
	1-28-2020 10:15:00 AM	LT1	LT1	
	3-2-2020 10:20:00 AM	<u>LT1</u>	<u>LT1</u>	
	<b>Total Positive:</b>	<b>0</b>	<b>0</b>	<b>0</b>

**Result Values:**                      E - estimated                      L - less than                      G - greater than

Samples that contain total coliform:	0	0.00% of total
Samples that contain e. coli:	0	0.00% of total
Samples that contain fecal coliform:	0	0.00% of total
Number of consecutive samples that contain total coliform:	0	
Number of samples that contain total coliform in last 30 days:	0/0	
Total number of samples:	2	

**Comments:**

\_\_\_\_\_  
Environmental Health Officer  
Jan 20 2021

FOR FURTHER INFORMATION PLEASE CALL: Binny Sivia

## Sample Range Report

Fraser Health Authority

**Facility Name:** Whonnock Lake Park WS  
**Date Range:** Jan 1 2020 to Dec 31 2020

**Operator** Michael Albrecht  
 11995 Haney PI  
 Maple Ridge, BC V2X 6A9

Sampling Site	Date Collected	Total Coliform	E. Coli	Fecal Coliform
<u>AUDIT, 27871 113</u>				
<u>Ave</u>				
	1-28-2020 10:00:00 AM	LT1	LT1	
	6-2-2020 10:05:00 AM	LT1	LT1	
	7-15-2020 9:05:00 AM	LT1	LT1	
	9-28-2020 1:03:00 PM	LT1	LT1	
	11-30-2020 9:45:00 AM	<u>LT1</u>	<u>LT1</u>	
	<b>Total Positive:</b>	<b>0</b>	<b>0</b>	<b>0</b>

**Result Values:**                      E - estimated                      L - less than                      G - greater than

Samples that contain total coliform:	0	0.00% of total
Samples that contain e. coli:	0	0.00% of total
Samples that contain fecal coliform:	0	0.00% of total
Number of consecutive samples that contain total coliform:	0	
Number of samples that contain total coliform in last 30 days:	0/0	
Total number of samples:	5	

**Comments:**

\_\_\_\_\_  
 Environmental Health Officer  
 Jan 20 2021

FOR FURTHER INFORMATION PLEASE CALL: Binny Sivia



**fraserhealth** Better health.  
Best in health care.

February 1, 2021

*Water System Operators*

**Re: Metals in Drinking Water – “Flush” Message in Annual Reports**

---

Fraser Health has recently revised its metals at the tap “Flush” message and we are asking all water systems to please include the following health message with your next annual reports to your users.

***Anytime the water in a particular faucet has not been used for six hours or longer, “flush” your cold-water pipes by running the water until you notice a change in temperature. (This could take as little as five to thirty seconds if there has been recent heavy water use such as showering or toilet flushing. Otherwise, it could take two minutes or longer.) The more time water has been sitting in your home's pipes, the more lead it may contain.***

***Use only water from the cold-tap for drinking, cooking, and especially making baby formula. Hot water is likely to contain higher levels of lead.***

***The two actions recommended above are very important to the health of your family. They will probably be effective in reducing lead levels because most of the lead in household water usually comes from the plumbing in your house, not from the local water supply.***

***Conserving water is still important. Rather than just running the water down the drain you could use the water for things such as watering your plants.***

If you have any questions, please contact our Drinking Water Program at 604-870-7903.

Sincerely,

Drinking Water Program  
Fraser Health Authority  
HPLand@fraserhealth.ca